



Note: Most underground transmission lines would require only a single trench, but the NESJ Line is proposed to be a double circuit line with bundled conductors (2 wires at each position) so two separate trenches are required for each circuit.

Northeast San Jose Transmission Reinforcement Project EIR

Figure B-7

Generalized Cross-Section of Underground Transmission Line

Aspen
Environmental Group